

**Large Load = All services over 225A**

**\*\*Instrument Rated (CT) padmount transformer services SHALL meet section 1.8.4 of the AEDCM\*\***

**Service Voltage: 120/240V Three Phase Delta Service**

**For services with a maximum manufacture nameplate handle(s) rating  
Above 3000 amps and Up to 4000 amps.**

**Meter Socket:**

**Milbank**

UC4662-0-WCB-21-AE

**Eaton**

STL13-1A120-CH

**Schneider**

STL13-1A120-SQD

**Durham**

STL13-1A120

**Midwest**

STL13-1A120-MEP

**Tesco**

9070451

**Texas Meter Device**

602U3010A13-1556

**Current Transformer (CT) Ratio:**

**Peak Demand**

2000/5 Bushing COV2000ANN COV-6

**ABB**

2000/5 Bushing 923A497G03 CMV-S

**RITZ**

4000/5 Bushing 110601011.0253