

**Large Load = All services over 225A**

**\*\*Instrument Rated (CT) padmount transformer services SHALL meet section 1.8.4 of the AEDCM\*\***

**Service Voltage: 277/480V**

**For services with a maximum manufacture nameplate handle(s) rating  
Above 1200 amps and Up to 3000 amps.**

**Meter Socket:**

**Texas Meter Device**

622-8085A13-1753

**Tesco**

9060001-CL

**Durham**

1012977

**VT Pack:**

**TSTM**

2.5/1 6003012

**RITZ**

2.5/1 120601040.0991

**Current Transformer (CT) Ratio:**

**Peak Demand**

2000/5 Bushing COV2000ANN COV-6

**Ritz**

2000/5 Bushing 1106011011.0823 DCDW

**ABB**

2000/5 Bushing 923A497G03 CMV-S

**Arteche**

2000/5 Bushing 735320260 IRH-7

**GE**

2000/5 Bushing 750X336102 JAB-OS