

**Large Load = All services over 350A**  
**\*\*Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)\*\***

**Service Voltage: 120/208V Single Phase**

**For services with a maximum manufacture nameplate handle(s) rating Above 600 amps and up to 1200 amps, the customer SHALL build/install a conventional instrument rated (CT) service**

**Meter Socket:**

**Milbank**

UC-4666-0-WCB-21

**Durham**

STL6-1A433

**Schneider**

STL6-1A433-SQD

**Eaton/Durham**

STL6-1A433-CH

**Midwest**

STL6-1A433-MEP

**Tesco**

9070577

**Texas Meter Device**

602U3010A6-1555

**Current Transformer (CT) Ratio:**

**Peak Demand**

600/5 Medium Window COM0600ABN-X COM-6

**Ritz**

600/5 Medium Window 110601008.0801 DCCW

**GE**

600/5 Medium Window 750X333002 JAK-OS

**ABB**

600/5 Medium Window 923A497G04 CMF-S

**Artechce**

600/5 Medium Window 735300120 IRH-5

**Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):**

**36x36x14**