

**Large Load = All services over 350A**  
**\*\*Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)\*\***

**Service Voltage: 120/208V Single Phase**

**For services with a maximum manufacture nameplate handle(s) rating Above 2000 amps and up to 3500 amps, the customer SHALL build/install a conventional instrument rated (CT) service**

**Meter Socket:**

**Milbank**

UC-4666-0-WCB-21

**Durham**

STL6-1A433

**Schneider**

STL6-1A433-SQD

**Eaton/Durham**

STL6-1A433-CH

**Midwest**

STL6-1A433-MEP

**Tesco**

9070577

**Texas Meter Device**

602U3010A6-1555

**Current Transformer (CT) Ratio:**

**Peak Demand**

2000/5 Large Window COL2000ABN COL-6

**ABB**

2000/5 Large Window 923A533G01 CLC-S

**Arteche**

2000/5 Large Window 735360210 IRH-12

**Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):**

**60x60x16**