

**Large Load = All services over 225A**

**\*\*Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)\*\***

**Service Voltage: 120/208V Three Phase, 4 Wire Wye**

**For services with a maximum manufacture nameplate handle(s) rating**

**Above 1200 amps and up to 1600 amps, the customer SHALL build/install a conventional instrument rated (CT) service**

**Meter Socket:**

**Milbank**

UC4662-0-WCB-21-AE

**Eaton**

STL13-1A120-CH

**Schneider**

STL13-1A120-SQD

**Durham**

STL13-1A120

**Midwest**

STL13-1A120-MEP

**Tesco**

9070451

**Texas Meter Device**

602U3010A13-1556

**Current Transformer (CT) Ratio:**

**Peak Demand**

2000/5 Large Window COL2000ABN COL-6

**Ritz**

2000/5 Large Window 110601012.0817 DCEW

**ABB**

2000/5 Large Window 923A533G01 CLC-S

**Arteche**

2000/5 Large Window 735360210 IRH-12

**Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):**

**42x42x14**