

Large Load = All services over 225A

****Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)****

Service Voltage: 120/208V Three Phase, 4 Wire Wye

For services with a maximum manufacture nameplate handle(s) rating Above 600 amps and up to 1200 amps, the customer SHALL build/install a conventional instrument rated (CT) service

Meter Socket:

Milbank

UC4662-0-WCB-21-AE

Eaton

STL13-1A120-CH

Schneider

STL13-1A120-SQD

Durham

STL13-1A120

Midwest

STL13-1A120-MEP

Tesco

9070451

Texas Meter Device

602U3010A13-1556

Current Transformer (CT) Ratio:

Peak Demand

600/5 Medium Window COM0600ABN-X COM-6

Ritz

600/5 Medium Window 110601008.0801 DCCW

GE

600/5 Medium Window 750X333002 JAK-OS

ABB

600/5 Medium Window 923A497G04 CMF-S

Arteche

600/5 Medium Window 735360210 IRH-12

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):

36x36x14