

Large Load = All services over 350A

****Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)****

Service Voltage: 120/240 Single Phase

**For services with a maximum manufacture nameplate handle(s) rating
Above 1200 amps and up to 1600 amps, the customer SHALL build/install a conventional instrument rated (CT) service**

Meter Socket:

Milbank

UC-4666-0-WCB-21

Durham

STL6-1A433

Schneider

STL6-1A433-SQD

Eaton/Durham

STL6-1A433-CH

Midwest

STL6-1A433-MEP

Tesco

9070577

Texas Meter Device

602U3010A6-1555

Current Transformer (CT) Ratio:

Peak Demand

2000/5 Large Window COL2000ABN COL-6

Ritz

2000/5 Large Window 110601012.0817 DCEW

ABB

2000/5 Large Window 923A533G01 CLC-S

Arteche

2000/5 Large Window 735360210 IRH-12

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):

42x42x14