Large Load = All services over 350A
Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)

Service Voltage: 120/240 Single Phase

For services with a maximum manufacture nameplate handle(s) rating
Above 1200 amps and up to 1600 amps, the customer SHALL build/install a conventional instrument rated (CT) service

Meter Socket:
Milbank
UC-4666-0-WCB-21
Durham
STL6-1A433
Schneider
STL6-1A433-SQD
Eaton/Durham
STL6-1A433-CH
Midwest
STL6-1A433-MEP
Tesco
9070577
Texas Meter Device
602U3010A6-1555

Current Transformer (CT) Ratio:
Peak Demand
2000/5 Large Window COL2000ABN COL-6
Ritz
2000/5 Large Window 110601012.0817 DCEW
ABB
2000/5 Large Window 923A533G01 CLC-S
Arteche
2000/5 Large Window 735360210 IRH-12

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):
42x42x14