

Large Load = All services over 350A

****Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)****

Service Voltage: 120/240 Single Phase

For services with a maximum manufacture nameplate handle(s) rating
Above 600 amps and up to 1200 amps, the customer SHALL build/install a conventional instrument rated (CT) service

Meter Socket:

Milbank

UC-4666-0-WCB-21

Durham

STL6-1A433

Schneider

STL6-1A433-SQD

Eaton/Durham

STL6-1A433-CH

Midwest

STL6-1A433-MEP

Tesco

9070577

Texas Meter Device

602U3010A6-1555

Current Transformer (CT) Ratio:

Peak Demand

600/5 Medium Window COM0600ABN-X COM-6

Ritz

600/5 Medium Window 110601008.0801 DCCW

GE

600/5 Medium Window 750X333002 JAK-OS

ABB

600/5 Medium Window 923A497G04 CMF-S

Artehce

600/5 Medium Window 735300120 IRH-5

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):

36x36x14