

Large Load = All services over 225A
****Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)****

Service Voltage: 120/240V Three Phase, 4 Wire Delta Service

For services with a maximum manufacture nameplate handle(s) rating Above 1600 amps and up to 2000 amps, the customer SHALL build/install a conventional instrument rated (CT) service

Meter Socket:

Milbank

UC4662-0-WCB-21-AE

Eaton

STL13-1A120-CH

Schneider

STL13-1A120-SQD

Durham

STL13-1A120

Midwest

STL13-1A120-MEP

Tesco

9070451

Texas Meter Device

602U3010A13-1556

Current Transformer (CT) Ratio:

Peak Demand

2000/5 Large Window COL2000ABN COL-6

Ritz

2000/5 Large Window 110601012.0817 DCEW

ABB

2000/5 Large Window 923A533G01 CLC-S

Arteche

2000/5 Large Window 735360210 IRH-12

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):

48x48x14