

**Large Load = All services over 225A**  
**\*\*Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)\*\***

**Service Voltage: 120/240V Three Phase, 4 Wire Delta Service**

**For services with a maximum manufacture nameplate handle(s) rating**  
**Above 600 amps and up to 1200 amps, the customer SHALL build/install a conventional instrument rated (CT)**  
**service**

**Meter Socket:**

**Milbank**

UC4662-0-WCB-21-AE

**Eaton**

STL13-1A120-CH

**Schneider**

STL13-1A120-SQD

**Durham**

STL13-1A120

**Midwest**

STL13-1A120-MEP

**Tesco**

9070451

**Texas Meter Device**

602U3010A13-1556

**Current Transformer (CT) Ratio:**

**Peak Demand**

600/5 Medium Window COM0600ABN-X COM-6

**Ritz**

600/5 Medium Window 110601008.0801 DCCW

**GE**

600/5 Medium Window 750X333002 JAK-OS

**ABB**

600/5 Medium Window 923A497G04 CMF-S

**Arteche**

600/5 Medium Window 735360210 IRH-12

**Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):**

**36x36x14**