

Large Load = All services over 225A
****Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)****

Service Voltage: 277/480V Three Phase, 4 Wire Wye

For services with a maximum manufacture nameplate handle(s) rating Above 600 amps and up to 1200 amps, the customer SHALL build/install a conventional instrument rated (CT) service

Meter Socket:

Texas Meter Device

622-8085A13-1753

Tesco

9060001-CL

Durham

1012977

VT Pack:

TSTM

2.5/1 6003012

RITZ

2.5/1 120601040.0991

Current Transformer (CT) Ratio:

Peak Demand

600/5 Medium Window COM0600ABN-X COM-6

Ritz

600/5 Medium Window 110601008.0801 DCCW

GE

600/5 Medium Window 750X333002 JAK-OS

ABB

600/5 Medium Window 923A497G04 CMF-S

ARTHECHE

600/5 Medium Window 735300120 IRH-5

Minimum CT enclosure size (CT enclosure shall meet AEDCM section 1.9.1.9 requirements):

42x42x14