

**Large Load = All services over 225A**  
**\*\*Instrument Rated (CT) services SHALL have LOAD side main disconnect(s)/breaker(s)\*\***

**Service Voltage: 277/480V Three Phase, 4 Wire Wye**

**For services with a maximum manufacture nameplate handle(s) rating Above 225 amps and up to 600 amps, the customer SHALL use an AE approved transocket.**

**\*\*The customer is required to purchase a Voltage Transformer (VT) enclosure, VT Pack, and a VT Harness. Austin Energy will install the VT Pack and VT Harness.\*\***

**Meter Socket (Transocket):**

<b>Durham</b>
1012997
<b>Texas Meter Device</b>
TMD-600-9-AE
<b>Tesco</b>
920084

**Voltage Transfmer (VT) Enclosure**

<b>TSTM</b>
TS-LNG S6239-XL TSTM **or NEMA 3 lockable encloure with minium dimensions: Width 10 1/2", Height 20 1/8", Deep 5 1/4**
Terminal Strip 4#10-TS-B

**VT Pack:**

<b>TSTM</b>
2.5/1 6003012
<b>RITZ</b>
2.5/1 120601040.0991

**VT Harness**

<b>TSTM</b>
Meter socket Wiring Harness WH-PTS-AE-4832
Wiring Harness 6 ft WH-AE-6
Wiring Harness 12 ft WH-AE-12
<b>RITZ</b>
Wiring Harness 6 ft WH-3P4W-6-Austin2
Wiring Harness 12 ft WH-3P4W-12-Austin