

SPECIFICATION E-698  
QPL # EL-261  
Revised February 27, 1979  
Revised April 9, 1981

CITY OF AUSTIN, TEXAS  
PURCHASE SPECIFICATIONS FOR  
FLAT COPPER BUS BAR

1.0 SCOPE AND CLASSIFICATION

- 1.1 The item to be purchased under these specifications shall be flat copper bus bar.
- 1.2 No deviation from these specifications on the part of the bidder will be allowed.
- 1.3 Any items supplied under these specifications not in complete compliance with these specifications shall be unacceptable.

2.0 APPLICABLE SPECIFICATIONS

- 2.1 The equipment furnished under these specifications shall be designed, tested and manufactured in accordance with the applicable sections of ASTM specifications.

3.0 PHYSICAL REQUIREMENTS

- 3.1 All bus bar furnished under these specifications shall be copper.
- 3.2 Bus bar shall be flat with rounded edges. Dimensions to be 1/4" x 4" or 3/8" x 6".

4.0 GENERAL

- 4.1 Bus bar furnished under these specifications shall be furnished in exact 12' - 0" lengths unless otherwise specified on purchase order.